



ETA-Danmark A/S
Göteborg Plads 1
DK-2150 Nordhavn
Tel. +45 72 24 59 00
Internet www.etadanmark.dk

Authorised and notified according
to Article 29 of the Regulation (EU)
No 305/2011 of the European
Parliament and of the Council of 9
March 2011

MEMBER OF EOTA



European Technical Assessment ETA-24/0728 of 2024/08/27

I General Part

Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: ETA-Danmark A/S

Trade name of the construction product:

LIP Foliesystem 35

Product family to which the above construction product belongs:

Watertight covering kit for wet room floors and walls based on flexible sheets

Manufacturer:

LIP Bygningsartikler A/S
Industrivej 16
5580 Nørre Aaby
Telephone +45 64 42 13 30
Internet www.lip.dk

Manufacturing plant:

LIP Bygningsartikler A/S
Industrivej 16
5580 Nørre Aaby

This European Technical Assessment contains:

9 pages including 1 annex which form an integral part of the document

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of:

EAD 030436-00-0503 Watertight covering kits based on flexible sheets for wet room floors and or walls

This version replaces:

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full (excepted the confidential Annex(es) referred to above). However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

II SPECIFIC PART OF THE EUROPEAN TECHNICAL ASSESSMENT

1 Technical description of product

General

LIP Foliesystem 35 is a flexible sheet membrane kit which serves as a watertight covering for wet room floors and walls beneath a wearing surface. The kit consists of the following components:

Primer

LIP Primer, which is a single component water-based primer for various substrates, see technical data sheet. This primer is not intended to have a significant additional function in limiting the water vapour permeability of the kit.

Membrane

LIP Folie G35 is a 3-ply waterproof membrane consisting of two outer layers of polypropylene non-woven and an inner layer of modified low-density polyethylene. The average thickness of the membrane is $0,50 \pm 0,10$ mm and the weight is 179-221 g/m². The membrane is adhered to the substrate with 0,75 kg/m² LIP 2K Folielim or 0,25 kg/m² LIP 745 Gulv- og væglim (adhesive).

Joint in the sheet are adhered with 0,75 l/m² LIP Folielim or with 80 ml/m/50 mm wide overlap LIP Skarvlim MSP.

Reinforcement

The reinforcements are LIP ÅT Självhäftanderemsa, LIP Åt-Remsa, LIP FX-Remsa and LIP prefabricated inner and outer corners LIP “Åt-innerhörn” and LIP “Åt-ytterhörn”, which are used in connection between the floor and the wall, in corners and around penetrations. Sealing around pipe penetrations is made with LIP “Rørmanchet” or LIP “Rørmanchet Flex”, which is a prefabricated collar made of thermoplastic elastomers. Sealing of floor gullies is made with LIP “Afløbsmanchet”, which is a butyl based self-adhering collar. The reinforcements are not intended to cover the entire floor and wall covering but are used over joints and in corners and around pipe penetrations.

Adhesives

Adhesives covered by this ETA is: LIP Naturstensklæb; LIP Multi Fliseklæb, LIP Multi Let 544, LIP 527 Fliseklæb, LIP Trope Fliseklæb and LIP Hurtighærdende Fliseklæb or LIP XXL.

Kit

The kit is constructed as follows:

- LIP Primer is to be used for highly porous substrates or as an adhesive promotor for non-porous materials (amount depending on substrate).
- reinforcement of in- and out-going corners in walls, over joints or cracks in the substrate, around pipe penetrations, floor gullies and along the connection between floor and wall with reinforcement LIP ÅT Självhäftanderemsa, LIP Åt-Remsa, LIP FX-Remsa, LIP “Åt-innerhörn” and LIP “Åt-ytterhörn”, LIP “Rørmanchet” or LIP “Rørmanchet Flex” and LIP “Afløbsmanchet”.
- LIP Folie G35 adhered to the substrate with approx. 0,75 kg/m² LIP 2K Folielim, 0,25 l/m² LIP 745 Gulv- og væglim, and joints in the sheet adhered with 0,75 kg/m² LIP 2K Folielim or with 80 ml/m/50 mm wide overlap LIP Skarvlim MSP
- a layer of ceramic tiles adhered to the kit with cement-based tile adhesive (LIP Naturstensklæb, LIP Multi Fliseklæb, LIP Multi Let 544, LIP 527 Fliseklæb, LIP Trope Fliseklæb, LIP Hurtighærdende Fliseklæb or LIP XXL).

2 Specification of the intended use(s) in accordance with the applicable European Assessment Document (hereinafter EAD)

The intended use of the covering kit is:

1. watertight covering for use beneath a wearing surface, normally in the form of tiles, on substrates of gypsum boards, fibre cement boards, cement bonded boards and concrete, i.e. moisture sensitive substrates, which are flexible and with jointing and susceptible to cracking

The kit can be used with the following types of floor gullies:

Circular and rectangular gullies made from stainless steel or plastic type PE, with flange for adhesion of the membrane or with clamping ring or with collar

2. Indoor applications, where the liquid applied, kit is not exposed to temperatures (i.e., temperature of structure) below 5 °C and above 40 °C, in the following uses:

- Floor and wall surfaces with only occasional direct exposure to water, e.g., at a good distance from shower or bathtub.
- Floors and walls in shower areas or around bathtubs used for a few showers daily, e.g., in ordinary dwellings, multi-family houses and hotels
- Floor and wall surfaces with exposure to water

more frequent or of longer duration than normally anticipated in dwellings, e.g., public wet rooms, schools and sport facilities.

The provisions made in this European Technical Assessment are based on an assumed intended working life of the kit of 25 years.

The indications given on the working life cannot be interpreted as a guarantee given by the producer or Assessment Body but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

Characteristic	Assessment of characteristic
3.2 Safety in case of fire (BWR2)	
Reaction to fire	No performance assessed
3.3 Hygiene, health and the environment (BWR3)	
Content, emission and/or release of dangerous substances	No performance assessed
Vapour permeability	The s_d value of the membrane at RH 100 → 75 % is 92 m The values are for the flexible sheet alone, and the other components of the kit are not considered to have an adverse effect on these values.
Water tightness	Watertight
Crack bridging ability	Assessment category 3: Crack width 1,5 mm
Bond strength	LIP Primer, LIP Folie G35 and LIP 2K Folielim and tile adhesive LIP XXL Fliseklæb, LIP Multi Fliseklæb, LIP Naturstens klæber, LIP TROPE Fliseklæb, LIP 527 Fliseklæb, LIP Multi Let 544 and LIP Hurtighærdende Fliseklæb on substrates of fibre cement boards, cement based boards comply with Assessment category 3: Bond strength $\geq 0,5$ MPa LIP Primer, LIP Folie G35 and LIP 2K Folielim and tile adhesive LIP XXL Fliseklæb, LIP Multi Fliseklæb, LIP Naturstens klæber, LIP 527 Fliseklæb, LIP TROPE Fliseklæb, LIP Multi Let 544 and LIP Hurtighærdende Fliseklæb on substrates of gypsum boards, fibre cement boards, cement based boards comply with Assessment category 1: Bond strength $\geq 0,2$ MPa
Scratching resistance	Not relevant
Joint bridging ability	The kit can bridge joints
Water tightness around penetrations	Watertight
Resistance to temperature	Tensile strength longitudinal direction (after exposure): 305 N/50 mm (x = -1,2%) Tensile strength transverse direction (after exposure): 191 N/50mm (x = -10%) Elongation, longitudinal direction (after exposure): x = 55,7% (x = -11,7%) Elongation, transverse direction (after exposure): x = 91,7% (x = -2,1%)

Characteristic	Assessment of characteristic
Resistance to water	LIP Folie G35 and 0,75 kg/m ² LIP Folielim or 80 ml/m/50 mm wide overlap LIP Skarvlim MSP and tile adhesive LIP Naturstensklæb, LIP Multi Fliseklæb, Multi Let 544, LIP 527 Fliseklæb, LIP Trope Fliseklæb and LIP Hurtighærdende Fliseklæb on a substrate of gypsum boards, fibre cement boards, cement-based boards Assessment category 1: Bond strength > 0,2 Mpa LIP Primer, LIP Folie G35 and tile adhesive LIP XXL on substrates of gypsum boards, fibre cement boards, cement based boards comply with Assessment category 3: Bond strength ≥ 0,5 MPa
Resistance to alkalinity	Assessment category 3: Ageing of the sample at 23°C for 16 weeks. Derivation from unaged material : Tensile strength : Longitudinal direction : -0,14% Cross direction : -4,3% Tensile elongation : Longitudinal direction : 5,6% Cross direction : 9,7%
Resistance to mechanical wear	Not relevant
Joint strength	Applied with LIP Primer, LIP 2K Folielim Joint parallel to MD: 356 N Joint transverse to MD: 172 N Applied with LIP Primer, LIP Skarvlim MSP Joint parallel to MD: 367 N Joint transverse to MD: 174 N
Flexibility	No cracking or other surface deterioration visible
3.4 Safety in use (BWR4)	
Slipperiness	Not relevant
Cleanability	Not relevant
Thickness	The thickness of the LIP Folie G35 is assessed to be 0,50±0,1 mm

See additional information in section 3.9.

3.9 Aspects related to the performance of the product.

The European Technical Assessment is issued for the product on the basis of agreed data/information, deposited with ETA-Danmark, which identifies the product that has been assessed and judged. Changes to the product or production process, which could result in this deposited data/information being incorrect, should be notified to ETA-Danmark before the changes are introduced. ETA-Danmark will decide whether or not

such changes affect the ETA and consequently the validity of the CE marking on the basis of the ETA and if so whether further assessment or alterations to the ETA, shall be necessary.

The performance of the watertight membrane kit results from the characteristic values and categories.

The supplementing statements of the manufacturer stated in the MTD for design and application of the watertight system for creating a watertight covering under wearing surface for floors and walls in indoor wet areas shall be considered

The performance of the watertight membrane can be assumed only, if the following aspects are considered:

- only those components which are specified components of the kit can be used,
- the appropriate tools shall be used and adjuvant, precautions shall be taken,
- inspecting the substrate surface for cleanliness and correct treatment,
- inspection in the process of establishing the kit and of the finished watertight membrane and documentation of the results.

The information as to the handling of waste products shall be observed.

It is the manufacturer's responsibility to make sure that all those who utilize the kit will be appropriately informed about the specific conditions according to this ETA and the not confidential parts of the MTD deposited to this ETA.

4 Assessment and verification of constancy of performance (hereinafter AVCP) system applied, with reference to its legal base

4.1 AVCP system

According to the decision 2003/655/EC of the European Commission as amended, the system(s) of assessment and verification of constancy of performance (see Annex V to Regulation (EU) No 305/2011) is 2+.

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at ETA-Danmark prior to CE marking

Issued in Copenhagen on 2024-08-27 by



Thomas Bruun
Managing Director, ETA-Danmark

Components of the kit:

1. Primer depedning on substrate
2. LIP 2K Folielim or LIP 745 Gulv- og væglim (adhesive)
3. LIP Folie G35
4. LIP Reinforcement/LIP 2K Folielim/ LIP Skarvlim MSP
5. Tile adhesive and tile



LIP Foliessystem 35 watertight covering kit	Annex 1
Principle build-up of the kit	of European Technical Assessment ETA-16/0182